



LCRA Environmental Laboratory Services
 3505 Montopolis Drive
 Austin, TX 78744
 (512)730-6022
 (512)730-6021

ANALYTICAL RESULTS

Workorder: Q1830513

Lab ID: Q1830513003	Date Received: 8/2/2018 08:10	Matrix: Drinking Water
Sample ID: 1817649	Date Collected: 8/1/2018 11:40	Sample Type: SAMPLE
Facility: EP004	Location: WELL 4 - PH	
Sample: TRT-TAP	Client ID: TX2120009	

Parameter	Result	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qual
E300.0, Anions											
Analysis Desc: E300.0, Anions											
Chloride	5.14	mg/L	1.00	0.500		1			08/02/18 18:41		ML
Fluoride	0.101	mg/L	0.0100	0.00500	4	1			08/02/18 18:41		ML
Nitrate (as N)	0.0190	mg/L	0.0100	0.00500	10	1			08/02/18 18:41		ML
Sulfate	8.72	mg/L	1.00	0.500		1			08/02/18 18:41		ML
SM2320B, Alkalinity											
Analysis Desc: SM2320B, Alkalinity											
Phenolphthalein Alkalinity	0.00	mg/L	0.00	0.00		1			08/07/18 00:00		ADG N
Hydroxide Alkalinity	0.00	mg/L	0.00	0.00		1			08/07/18 00:00		ADG N
Bicarbonate Alkalinity	81.4	mg/L	0.00	0.00		1			08/07/18 00:00		ADG N
Carbonate Alkalinity	0.00	mg/L	0.00	0.00		1			08/07/18 00:00		ADG N
Total Alkalinity (CaCO3)	81.4	mg/L	20.0	20.0		1			08/07/18 00:00		ADG N
SM2510B, Conductivity @ 25°C											
Analysis Desc: SM2510B, Conductivity @ 25°C											
Specific Conductance	200	umho/cm	10.0	10.0		1			08/06/18 09:47		ME
SM2540C, TDS											
Analysis Desc: SM2540C, TDS											
Total Dissolved Solids(TDS)	131	mg/L	25.0	10.0		10			08/03/18 11:31		ADG